



Addendum No.1- ITB NO- UNDPAFG/UNOCHA/ITB/2011/ 0193

FOR

CONSTRUCTION WORKS FOR MOSS COMPLIANT AND UPGRADING OF UNOCHA NEW OFFICE IN QALA-E-FATULLAH, KABUL, AFGHANISTAN

Further to the issue of the TIB document for *CONSTRUCTION WORKS FOR MOSS COMPLIANT AND UPGRADING OF UNOCHA NEW OFFICE IN QALA-E-FATULLAH, KABUL, AFGHANISTAN* , the following amendment is made to the ITB documents:

UNDP & UNOCHA arranged a pre- bid conference to fully describe the BOQ, Drawing and bidding documents of the mentioned ITB on 15- November-2010, 14:00 pm at UNDP country office .Minutes of the pre bid meeting attached as Annex-I

Bidders are required to acknowledge the receipt of the Addendum to the following e-mail address and also indicate your interest to submit ITB Documents:

procurement.af@undp.org

Acknowledgement of Receipt of AddendumN0- 1

ITB NO- UNDPAFG/UNOCHA/ITB/2011/ 0193

FOR

CONSTRUCTION WORKS FOR MOSS COMPLIANT AND UPGRADING OF UNOCHA NEW OFFICE IN QALA-E-FATULLAH, KABUL, AFGHANISTAN

Addendum No. 1 has been received and incorporated in the Tender Documents.

Name of Bidder
(in block letters):

Date:

Signed for the Bidder by:

Annex-I

Minutes of Pre-Bid Meeting

Date: 15 November 2011

Time: 14:00 AM

Subject: ITB for MOSS & Upgrading of OCHA-Afghanistan New Office in Kabul

Participants:

Eng. Shah Mahmood, Procurement Analyst, UNDP-Afghanistan

Eng. Syed Faridullah Farid, ERF Acting Manger, OCHA-Afghanistan

Representative of 18 Construction Companies

Place: UNDP Office in Kabul

Engineer Farid, representative of OCHA, explained the technical drawings and BoQ and Engineer Shah Mahmood explained the bid submission procedure and ITB documents.

During the explanation, the following questions raised and relevant answers & clarifications provided:

No.	Question	Answer
1	What is the Generator Rooms' dimensions and type of its Doors?	The Rooms are 3.3x4 m and doors are ordinary metal double doors with 2.5 m height and 3m width. (BoQ Item # 7)
2	The VIP parking is for how many vehicles?	It is 40 sqm, sub-base 35cm well compacted and surface covered with 15 cm crush/gravel for two armored land-cruisers (BoQ Item # 14)
3	What types are the main entrance sliding and swing gates and pedestrian gates?	The entrance both gates (sliding and swing) and pedestrian gates (entrance and emergency exit) are bullet and explosion proof metallic's as shown in drawings (BoQ Item # 9 and 10),. The new entrance gates should be installed after supplying of construction materials for the works in the compound.
4	Explain the water reservoir and its tower, and new tube well?	The new tube well is semi deep well. The existing metallic tower along with the reservoir to be removed from the present location and installed in the new position shown in the plan. The existing metallic tower could be used for new installation. ((BoQ Item # 5)
5	What is the purpose of RCC wall?	The RCC wall is a bumper/fender against blast and explosive car/truck attacks. The foundation is L – shape RCC foundation with 25 cm depth. ((BoQ Item # 15)

6	What should be the spacing between the steel bars in the grills?	The plain 12mm steel bars to be 15 cm center-to-center vertically and horizontally (BoQ Item # 12)
7	What is specification of Brick Masonry Wall on the Top of Existing Boundary Walls?	The brick wall is additional wall on the existing 3 walls between the office and neighbors. Height of the brick wall is one meter and 8 cm PCC (1:5) on the top of brick wall as capping. (BoQ Item # 17)
8	Please explain the specification of Steel Mesh/Screen Type Fence on the Walls between the office and neighbors' houses?	The steel screen is made of 4mm steel bars with 1 m height and covered by green clothes as grating screen. (BoQ Item # 20)
9	What are the Firing Posts dimensions?	The firing posts are 2.5x2.5 m and 1.5 m height, made from the sand filled bags/sacks, Thickness of the firing posts walls is at least 40 cm. (BoQ Item # 21)
10	What is the specification of safe room's iron sheets?	The iron sheets T=5 mm as bullet proof shield to be used for both windows covering and sliding doors. (BoQ Item # 11)